



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 5/11/09

Code 65-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

| | | |
|---|---------------------|-------------------------|
| Code Title Indiana Residential Code | | Edition 2009 |
| Section number and title E4101.5 | | Page 711 |
| Proponent Charlie Eldridge | Title Consultant | |
| Address 551 Grassy Ln., Indianapolis, IN 46217 | | Phone (317) 370-3444 |
| PROPOSED CODE CHANGE (Check One) | | |
| <input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution | | |
| <p>E4101.5 Disconnecting means. Each appliance shall be provided with a means to disconnect all ungrounded supply conductors. For fixed electric space-heating equipment, means shall be provided to disconnect the heater and any motor controller(s) and supplementary overcurrent-protective devices. Switches and circuit breakers used as a disconnecting means shall be of the indicating type. Disconnecting means shall be as set forth in Table E4101.5. <u>The disconnecting means shall have an ampere rating not less than 125 percent of the total load of the motors and heaters. The provision for locking or adding a lock to the disconnecting means shall be installed on or at the switch or circuit breaker used as the disconnecting means and shall remain in place with or without the lock installed.</u></p> | | |
| REASON AND FISCAL IMPACT | | |
| <p>This text was extracted from the 2005 Indiana Residential Code.</p> | | |
| REVIEW RECOMMENDATION | | |
| Approve | | |
| Disapprove | | |
| Approve as amended | | |
| Further Study | | |